



State of Utah

JON M. HUNTSMAN, JR.
Governor

GARY R. HERBERT
Lieutenant Governor

Department of Administrative Services

RICHARD K. ELLIS
Executive Director

Division of Facilities Construction and Management

F. KEITH STEPAN
Director

ADDENDUM #2

Date: 12 September 2006

To: Contractors

From: Michael A. Ambre, Project Manager, DFCM

Reference: Salt Lake Community College; Auto-Trades Re-Roof
DFCM Project No. 06019660

Subject: **Addendum No. 2**

| | | | |
|-------|----------------------------|----------|--------------|
| Pages | Addendum | 1 | page |
| | <u>Architectural Specs</u> | <u>1</u> | <u>pages</u> |
| | Total | 2 | pages |

Note: This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

1.1 GENERAL

- a. The Project Schedule has not been revised per this addendum.
- b. Attached is a 1 page document relating to changes to Architectural Drawings and Specifications.

ADDENDUM NO. 2

Date: September 11th, 2006

PROJECT:

Salt Lake Community College
Auto Trades building– Roofing Improvements
DFCM Project No. 06019660

ARCHITECT:

P+A ARCHITECTS
821 EAST KENSINGTON AVENUE
SALT LAKE CITY, UT 84105

The original Contract Documents issued for the above noted project are amended as noted in this Addendum. It shall be the sole responsibility of the bidder to appropriately disseminate this information to all concerned prior to the assigned bid time and date, and to coordinate the Addendum with the Contract Documents.

If there are still unresolved questions after examining this addendum, please submit those questions via telephone or facsimile as soon as possible so that an addendum can be issued to clarify those issues in a timely manner.

Architectural Drawings and Specifications:

1. All ½" Denz Deck as called out on architectural drawings and in specification section 07540 shall be changed to ½" Dens "Prime".
2. See specification section 07540-TPO SINGLE-PLY MEMBRANE ROOFING. See specification sections 2.1 manufacturers and section 2.4 insulation materials. All references to "Extruded-Polystyrene Board Insulation" to be changed to "Expanded Polystyrene Insulation"
3. See specification section 07540-TPO SINGLE-PLY MEMBRANE ROOFING. See specification section 2.4 insulation materials. Note, 2.5 lb minimum density of polystyrene insulation as noted in specification to be changed to 2.0 lb minimum density

General Information:

1. Stevens Roofing Systems, "Fastline Adhered" shall be approved as a adhesion system for the membrane roof to the Dens Prime deck.. "Fastline Adhered", must meet all requirements for the design of the roofing system specified.

End of Addendum 2